



LaMARCHE®

INVERTER FAILURE CONTACTS

OPTION 132

A single set of Form "C" contacts are provided to indicate loss of inverter output.

OPTION 130

Inverter Failure Contact with light.

ECN/DATE

**106 BRADROCK DRIVE
DES PLAINES, IL. 60018
(847) 299-1188
FAX:(847)299-3061**

ISSUE DATE: 12266 - 8/98

INSTRUCTION DRAWING NUMBER:

P25-**LOPT132/130-1**